

**BALTIMORE CITY PUBLIC SCHOOL SYSTEM (BCPSS).
DEPARTMENT OF FACILITIES.
MATERIALS MANAGEMENT/LOGISTICS OFFICE.
200 E. North Avenue
Baltimore, MD 21202**

ADDENDUM No. 6

March 12, 2007

Solicitation: BCS -07039

Bid Due Date – March 15, 2007, 11:00 A.M.

Provide Renovation Services of the Paul Laurence Dunbar High School #414.

TO THE BIDDERS: PLEASE ATTACH TO YOUR CONTRACT DOCUMENTS.

The following changes, additions, deletions and clarifications are hereby made part of the Contract Documents for the above referenced project and shall be taken into account in the preparation of the proposals and execution of all work. Vendors shall acknowledge receipt of this addendum on the Contract Proposal Form.

Notice: The following changes and additions should be considered as amendments to the above referenced bid documents.

Item #1.

Potential vendors for your information and clarification please use in preparation of your response to the solicitation BCS-07039 below listed additional information:

”Provide ATC system those ties into Johnson Controls Metasys system being installed under separate contract. New systems to have read/write capability via BACnet MS/TP from existing BCPSS Metasys workstation at Robb Street facility. Floor plan graphics to be included.” If any additional cost is required for modification to the ATC system it will be paid from 10% contingency fund via Change Order.

Item #2.

All additional electrical work, if required, will be financed from the 10% contingency fund via Change Order. This shall include but not limited to labor, material and equipment, required for a complete and finished job.

Item #3.

Whatever will be required to complete any of work included under section #01210 (Allowances) will be funded via Change Order financed from the 10% contingency. This shall include but not limited to labor, material and equipment, required for a complete finished job.

All other terms and conditions shall remain unchanged.

Failure to acknowledge and respond to this addendums on a form below (BID PROPOSAL DOCUMENT) may result in the proposal being considered non-responsive.